



City of Huntington Beach

**ADA Self Evaluation and Transition
Plan**

Public Works Commission
October 16, 2024

Background

- September 13, 2021 the City released a Proposal to hire a consultant to create an Americans with Disabilities Act (ADA) self-evaluation and transition plan. The previous plan was created in 2007 for park and building facilities.
- In February 2022 City hired Disability Access Consultants (DAC) to prepare an ADA Self-Evaluation and Transition Plan. DAC Consulting has prepared a similar report for the City of Fountain Valley, Fullerton, among others within the last five years.



Purpose of Study

- Prepare a transition plan that updated all parks and buildings and include right-of-way facilities, including parking lots and sidewalks.

The Federal Americans Disability Act (ADA)

- Has been in place since 1990 and the code of federal regulations mandates public agencies to comply by maintaining an up to date transition plan.



ADA Plan Process

- Takes approximately 2 to 3 years but we are ahead of schedule.
- DAC Progress and Tasks as of September 23,2024

B. Progress/Tasks

- | | |
|----------------------------------|---|
| 1. Expected Project Time Frame: | Contracted for 36 months |
| 2. Facilities/Parks Inspections: | Only beach restrooms remain for survey |
| 3. PROW Scoped: | Total of 600 linear sidewalk miles initially estimated
762 linear sidewalk miles completed (completed)
Note: Original scoped facility/park list has been adjusted over the course of the project to accommodate additional PROW surveys and added sites. |
| 4. Policy/Procedure Review: | Completed |
| 5. Public Input Responses: | Online surveys completed:
Public: 68 responses
Organizations: 6 responses
Staff: no responses |
| 6. Website Review: | Completed |

C. Next Steps


- | | |
|---------------------------|---|
| 1. Complete Facilities: | September 2024 |
| 2. Public Input: | Included in project executive summary report |
| 3. Policy/Program Review: | Included in project executive summary report |
| 4. Executive Summary: | Will be provided by October 11, 2024 |
| 5. DACTrak Training: | Scheduled for October 17, 2024 |
| 6. Next Meeting: | TBD <ul style="list-style-type: none">• suggested implementation strategy meeting following DACTrak training. |

Study Area

- 762 lineal foot of sidewalk surveyed
- 25 Building Facilities surveyed*
- 76 Parks surveyed**

*include associated parking lot if applicable

**includes associated buildings/parking if applicable



Existing Sample DACTrak ADA Software Inventory

Facilities and Parks

Project Information
Address : 11111 Brookshire Avenue Downey, CA 90241
Start Date : 10/21/2016

Facility List	
Apollo Park	12544 Rives Avenue Downey, CA 90242
Barbara J Riley Community Center	7810 Quill Drive Downey, CA 90240
Brookshire Childrens Park	12520 Brookshire Avenue Downey, CA 90240
Chamber of Commerce	11131 Brookshire Avenue Downey, CA 90240
City Hall	11111 Brookshire Avenue Downey, CA 90240
Crawford Park	7000 Dinwiddie Street Downey, CA 90240
Dennis The Menace Park	9125 Arrington Avenue Downey, CA 90240
Discovery Sports Complex Park	12400 Columbia Way Downey, CA 90242
Downey Civic Theatre	8435 Firestone Boulevard Downey, CA 90240
Furman Park	10419 Rives Avenue Downey, CA 90241
Gary P. McCaughan Gymnasium	12544 Rives Avenue Downey, CA 90242

Upon logging in to the secure DACTrak website, you are able to choose the facility you would like to view and manage. This screen shot is an example of a facility list for a recent public entity transition plan project.

Welcome, demonstration | Support | Sign Out

Projects: Facilities and Parks

Civic Center

Facility Information
Address : 2862 Orville

Reports

- Excel Report
- PDF Report
- KML Report
- Shape File Report
- Text Report
- Basic Photo Report
- Dual Photo Report
- Summary Report
- Transition Plan Report
- Total Unit Cost Report
- Corrected Items Report
- Map Overlay
- Summary and Chart Report
- Compliance Detail Report
- Multi Facility Reports
 - Excel Report
 - Total Estimated Cost Report
 - PDF Report
 - KML Report
 - Shape File Report
 - Text Report
 - Photo Report
 - Transition Plan Report
 - Map Overlay Report
 - CIS Heatmap
 - Summary and Chart Report
 - Compliance Detail Report
 - Compliance Summary Report
 - Intake Type Summary Report
 - Sidewalk Change in Elevation Report
 - Compliant Items Report

View All Photos
View Cover Page

After choosing a facility, you are able to use Reports drop down menu to choose which report style to view. You may also choose to view multiple facilities in one report.

Civic Center

Stairs

Record Number	Finding	Recommendation	Projected Date	Actual Date	Photo
20407	Stairs to Council Chambers General Seating - Left Run 1 The treads do not have a uniform depth.	Modify or replace the stairs to provide compliant treads.			
10.50 inches	Code At least 11.00 inches ADA 504.504.2, CA 11B-504.2	Priority Not Set Resolution Not Set Progress Not Set Assignment Not Set			
20408	Stairs to Council Chambers General Seating - Left Run 1 The risers on the stairway are not a compliant height.	Modify or replace the stairs to provide compliant riser height.			
7.75 inches	Code 4.00 - 7.00 inches ADA 504.2, CA 11B-504.2	Priority Not Set Resolution Not Set Progress Not Set Assignment Not Set			
20409	Stairs to Council Chambers General Seating - Left Run 1 The striping at the upper approach of the stairs is not a compliant width.	Affix compliant contrasting striping to the upper approach and each tread that is the correct width and distance from the nosing.			
None Found	Code ADA 504, CA 11B-504.4	Priority Not Set Resolution Not Set Progress Not Set Assignment Not Set			



ADA Projects throughout City

Projects recently provided

- ❑ ADA Sidewalk and Ramps in CIP
- ❑ ADA Sidewalk grinding in Street Maintenance
- ❑ Facility and Park upgrades in CIP



Questions?

