



Appropriate Funding for Hamilton and Slater Flood Station Repairs

City Council Meeting
November 7, 2023

Background

- City has 15 Flood Control Stations to mitigate flood risk in low elevation sections of the City.
- Hamilton Station Pump #1 failed after the final rain event of the season. Pumps #3 and #4 heat exchangers were determined to be undersized during the Summer Tropical Storm.
- Slater Station ingested a tire causing damage to Pump #1.



Hamilton Flood Station Damage



Slater Flood Station Damage



Requested Action

- Estimated cost for repairing both stations = \$210,000; Appropriation requested from Drainage Fund (211).
- Repairs expected to take 60 days.
- Failure to Repair These Stations Increases Flooding Risk to Area Streets, Residences and Business.

