

## **Citations From - DOMESTIC WATER SUPPLY PERMIT**

WHEREAS:

4. In April 2015, the U.S. Department of Health and Human Service Agency recommended that water systems practicing fluoridation adjust their fluoride content to 0.7 mg/L, as opposed to the previous temperature-dependent optimal levels ranging from 0.7 mg/L to 1.2 mg/L.

THE CITY OF HUNTINGTON BEACH IS HEREBY ISSUED THIS DOMESTIC WATER SUPPLY PERMIT TO OPERATE THE CITY OF HUNTINGTON BEACH WATER SYSTEM.

The City of Huntington Beach Water System (hereinafter, City) shall comply with the following permit conditions:

### ***Safe Drinking Water Act***

1. The City shall comply with all the requirements set forth in the California Safe Drinking

Water Act, California Health and Safety Code, and any regulations, standards or orders adopted thereunder.

### **Permit Amendment**

No changes, additions, or modifications shall be made to the sources or treatment processes outlined in Conditions 2 through 3 unless an amended water permit has first been obtained from the Division.

### **Treatment Plant Operation and Maintenance**

5. The treatment facilities specified above shall be operated in accordance with a Division-approved Operations Plans.

6. The City shall adjust fluoride levels at all fluoridation facilities to achieve an optimal fluoride level of 0.7 mg/L in each fluoridation facility effluent.

7. All treatment facilities shall be maintained in accordance with the manufacturer's specification

Any change in the source of water for the water system, any modification of the method of treatment as described in the Permit Report, or any addition of distribution system storage reservoirs shall not be made unless an application for such change is submitted to the State Water Resources Control Board - Division of Drinking Water.