



CITY OF HUNTINGTON BEACH

DEPARTMENT OF COMMUNITY DEVELOPMENT

PLANNING ♦ BUILDING ♦ PERMIT CENTER ♦ ECONOMIC DEVELOPMENT ♦ HOUSING ♦ CODE ENFORCEMENT

May 31, 2022

Elizabeth Wiktor
7241 Grandoaks Drive
Stanton, CA 90680

**SUBJECT: CONDITIONAL USE PERMIT NO. 22-006/VAR-22-002 (Diesel Auto Repair Facility)
PROJECT IMPLEMENTATION CODE REQUIREMENTS**

Dear Elizabeth Wiktor,

In order to assist you with your development proposal, staff has reviewed the project and identified applicable city policies, standard plans, and development and use requirements from the City of Huntington Beach Zoning & Subdivision Ordinance and Municipal Codes. This list is intended to help you through the permitting process and various stages of project implementation. Please note that if the design of your project or site conditions change, the list may also change.

If you would like a clarification of any of these requirements, an explanation of the City of Huntington Beach Zoning & Subdivision Ordinance or Municipal Codes, or if you believe some of the items listed do not apply to your project, and/or you would like to discuss them in further detail, please contact me at Alyssa.helper@surfcity-hb.org or 714-536-5438 and/or the respective source department (contact person below).

Sincerely,

Associate Planner
City of Huntington Beach

Enclosure

cc: Mehdi Taheri, PE, PhD, Building and Safety Department
Steve Eros, Fire Department
Jacob Aube, Public Works Department
Matthew Schneider, Planning Manager
Property Owner
Project File



HUNTINGTON BEACH COMMUNITY DEVELOPMENT DEPARTMENT PROJECT IMPLEMENTATION CODE REQUIREMENTS

DATE: MAY 31, 2022

PROJECT NAME: DIESEL AUTO REPAIR FACILITY

PLANNING APPLICATION NO. PLANNING APPLICATION NO. 22-0029

ENTITLEMENTS: CONDITIONAL USE PERMIT NO. 22-006/VARIANCE NO. 22-002

DATE OF PLANS: APRIL 26, 2022

PROJECT LOCATION: 7422 WARNER AVENUE, 92647 (SOUTHEAST CORNER OF WARNER AVENUE AND PALMDALE STREET)

PLAN REVIEWER: ALYSSA HELPER, ASSOCIATE PLANNER

TELEPHONE/E-MAIL: ALYSSA.HELPER@SURFCITY-HB.ORG; 714-536-5438

PROJECT DESCRIPTION: **CUP:** To establish a 2,000-square foot industrial building for automobile repair services on a vacant substandard lot that is 7,692 sq. ft. in size lieu of the minimum required lot area of 15,000 sq. ft. **VAR:** 1) to permit a 10-ft. front yard setback in lieu of an average 20-ft. front yard setback, 2) to permit a 2-ft.-wide interior landscape planter along the southern perimeter of the site in lieu of 3 ft., 3) to permit two parking spaces that are 9-ft. wide and 9.5-ft. wide in lieu of 12 ft., and 4) to eliminate the requirement to provide a 12-in.-wide by 3 ½-in.-thick step off area near planter areas adjacent to parking spaces.

The following is a list of code requirements deemed applicable to the proposed project based on plans stated above. The list is intended to assist the applicant by identifying requirements which must be satisfied during the various stages of project permitting and implementation. A list of conditions of approval adopted by the Planning Commission in conjunction with the requested entitlement(s), if any, will also be provided should final project approval be received. If you have any questions regarding these requirements, please contact the Plan Reviewer.

CONDITIONAL USE PERMIT NO. 22-006/ VARIANCE NO. 22-002:

1. The site plan, floor plans, and elevations approved by the Planning Commission shall be the conceptually approved design (with the following modifications).
 - a. Parking lot striping shall comply with Chapter 231 of the Zoning and Subdivision Ordinance and Title 24, California Administrative Code. **(HBZSO Chapter 231)**
 - b. The site plan shall include all utility apparatus, such as but not limited to, backflow devices and Edison transformers. Utility meters shall be screened from view from public right-of-ways.

Electric transformers in a required front or street side yard shall be enclosed in subsurface vaults. Backflow prevention devices shall be not be located in the front yard setback and shall be screened from view. **(HBZSO Section 230.76)**

- c. All exterior mechanical equipment shall be screened from view on all sides. Rooftop mechanical equipment shall be setback a minimum of 15 feet from the exterior edges of the building. Equipment to be screened includes, but is not limited to, heating, air conditioning, refrigeration equipment, plumbing lines, ductwork and transformers. Said screening shall be architecturally compatible with the building in terms of materials and colors. If screening is not designed specifically into the building, a rooftop mechanical equipment plan showing proposed screening must be submitted for review and approval with the application for building permit(s). **(HBZSO Section 230.76)**
 - d. The site plan and elevations shall include the location of all gas meters, water meters, electrical panels, air conditioning units, mailboxes (as approved by the United States Postal Service), and similar items. If located on a building, they shall be architecturally integrated with the design of the building, non-obtrusive, not interfere with sidewalk areas and comply with required setbacks. **(HBZSO Section 230.76)**
 - e. All parking area lighting shall be energy efficient and designed so as not to produce glare on adjacent residential properties. Security lighting shall be provided in areas accessible to the public during nighttime hours, and such lighting shall be on a time-clock or photo-sensor system. **(HBZSO 231.18.C)**
 - f. Bicycle parking facilities shall be provided in accordance with the provisions of HBZSO Section 231.20 – *Bicycle Parking*. **(HBZSO Section 231.20)**
2. Prior to issuance of demolition permits, the following shall be completed:
- a. The applicant shall follow all procedural requirements and regulations of the South Coast Air Quality Management District (SCAQMD) and any other local, state, or federal law regarding the removal and disposal of any hazardous material including asbestos, lead, and PCB's. These requirements include but are not limited to: survey, identification of removal methods, containment measures, use and treatment of water, proper truck hauling, disposal procedures, and proper notification to any and all involved agencies. **(AQMD Rule 1403)**
 - b. Pursuant to the requirements of the South Coast Air Quality Management District, an asbestos survey shall be completed. **(AQMD Rule 1403)**
 - c. The applicant shall complete all Notification requirements of the South Coast Air Quality Management District. **(AQMD Rule 1403)**
 - d. The City of Huntington Beach shall receive written verification from the South Coast Air Quality Management District that the Notification procedures have been completed. **(AQMD Rule 1403)**
 - e. The applicant shall provide a consulting arborist report on all the existing trees. Said report shall quantify, identify, size and analyze the health of the existing trees. The report shall also recommend how the existing trees that are to remain (if any) shall be protected and how far construction/grading shall be kept from the trunk. **(Resolution No. 4545)**

- f. Existing mature trees that are to be removed must be replaced at a 2 for 1 ratio with a 36" box tree or palm equivalent (13'-14' of trunk height for Queen Palms and 8'-9' of brown trunk). **(CEQA Categorical Exemption Section 15304)**
3. Prior to issuance of grading permits, the following shall be completed:
 - a. Prior to submittal of a landscape plan, the applicant shall provide a Consulting Arborist report on all the existing trees. Said report shall quantify, identify, size and analyze the health of the existing trees. The report shall also recommend how the existing trees that are to remain (if any) shall be protected and how far construction/grading shall be kept from the trunk. **(Resolution No. 4545)**
 - b. A Landscape and Irrigation Plan, prepared by a Licensed Landscape Architect shall be submitted to the Community Development Department for review and approval. **(HBZSO Section 232.04)**
 - c. Existing mature trees that are to be removed must be replaced at a 2 for 1 ratio with a 36" box tree or palm equivalent (13'-14' of trunk height for Queen Palms and 8'-9' of brown trunk). **(CEQA Categorical Exemption Section 15304)**
 - d. "Smart irrigation controllers" and/or other innovative means to reduce the quantity of runoff shall be installed. **(HBZSO Section 232.04.D)**
 - e. Standard landscape code requirements apply. **(HBZSO Chapter 232)**
 - f. All landscape planting, irrigation and maintenance shall comply with the City Arboricultural and Landscape Standards and Specifications. **(HBZSO Section 232.04.B)**
 - g. Landscaping plans should utilize native, drought-tolerant landscape materials where appropriate and feasible. **(HBZSO Section 232.06.A)**
 - h. A Consulting Arborist shall review the final landscape tree-planting plan and approve in writing the selection and locations proposed for new trees. Said Arborist signature shall be incorporated onto the Landscape Architect's plans and shall include the Arborist's name, certificate number and the Arborist's wet signature on the final plan. **(Resolution No. 4545)**
5. All new commercial development not covered by Chapter 254 of the Huntington Beach Zoning and Subdivision Ordinance shall pay a park fee. The fees shall be paid and calculated according to a schedule adopted by City Council resolution. **(City of Huntington Beach Community Development Department Fee Schedule)**
6. During demolition, grading, site development, and/or construction, the following shall be adhered to:
 - a. Existing street tree(s) to be inspected by the City Inspector during removal of concrete and prior to replacement thereof. Tree replacement or root/tree protection, will be specified upon the inspection of the root system. **(Resolution No. 4545)**
 - b. All Huntington Beach Zoning and Subdivision Ordinance and Municipal Code requirements including the Noise Ordinance. All activities including truck deliveries associated with construction, grading, remodeling, or repair shall be limited to Monday - Saturday 7:00 AM to 7:00 PM. Such activities are prohibited Sundays and Federal holidays. **(HBMC 8.40.090)**

7. The structure(s) cannot be occupied, the final building permit(s) cannot be approved, and utilities cannot be released for the commencement of use and issuance of a Certificate of Occupancy until the following has been completed:
 - a. The applicant shall stripe the parking lot to conform to provisions of Chapter 231 of the Huntington Beach Zoning & Subdivision Ordinance. **(HBZSO Chapter 231)**
 - b. A Certificate of Occupancy must be approved by the Community Development Department and issued by the Building and Safety Department. **(HBMC 17.04.036)**
 - c. Complete all improvements as shown on the approved grading, landscape and improvement plans. **(HBMC 17.05)**
 - d. All trees shall be maintained or planted in accordance to the requirements of Chapter 232. **(HBZSO Chapter 232)**
 - e. All landscape irrigation and planting installation shall be certified to be in conformance to the City approved landscape plans by the Landscape Architect of record in written form to the City Landscape Architect. **(HBZSO Section 232.04.D)**
 - f. One 36-inch box tree for each 45 lineal feet of street frontage shall be planted within the first 15 feet of the setback area adjacent to a street to meet the Huntington Beach; Zoning and Subdivision Ordinance, the Arboricultural and Landscape Standards and Specifications, and the Municipal Code. **(HBZSO Section 232.08, Resolution 4545, HBMC 13.50)**
 - g. The provisions of the Water Efficient Landscape Requirements shall be implemented. **(HBMC 14.52)**
8. The use shall comply with the following: Outdoor storage and display of merchandise, materials, or equipment, including display of merchandise, materials, and equipment for customer pick-up, shall be subject to approval of Conditional Use Permit. **(HBZSO Section 230.74)**
9. The Development Services Departments (Planning and Building, Fire, Planning and Public Works) shall be responsible for ensuring compliance with all applicable code requirements and conditions of approval. The Community Development Director may approve minor amendments to plans and/or conditions of approval as appropriate based on changed circumstances, new information or other relevant factors. Any proposed plan/project revisions shall be called out on the plan sets submitted for building permits. Permits shall not be issued until the Development Services Departments have reviewed and approved the proposed changes for conformance with the intent of the Planning Commission's /Zoning Administrator's action. If the proposed changes are of a substantial nature, an amendment to the original entitlement reviewed by the Planning Commission /Zoning Administrator may be required pursuant to the provisions of HBZSO Section 241.18. **(HBZSO Section 241.18)**
10. Conditional Use Permit No. 22-006 and Variance No. 22-002 shall become null and void unless exercised within one year of the date of final approval, or as modified by condition of approval. An extension of time may be granted by the Director pursuant to a written request submitted to the Planning Division a minimum 30 days prior to the expiration date. **(HBZSO Section 241.16.A)**
11. Conditional Use Permit No. 22-006 and Variance No. 22-002 shall not become effective until the appeal period following the approval of the entitlement has elapsed. **(HBZSO Section 241.14)**

12. The Planning Commission reserves the right to revoke Conditional Use Permit No. 22-006 and Variance No. 22-002 pursuant to a public hearing for revocation, if any violation of the conditions of approval, Huntington Beach Zoning and Subdivision Ordinance or Municipal Code occurs. **(HBZSO Section 241.16.D)**
13. The project shall comply with all applicable requirements of the Municipal Code, Planning and Building Department and Fire Department, as well as applicable local, State and Federal Fire Codes, Ordinances, and standards, except as noted herein. **(City Charter, Article V)**
14. The applicant shall submit a check in the amount of \$50.00 for the posting of the Notice of Exemption/Determination at the County of Orange Clerk's Office. The check shall be made out to the County of Orange and submitted to the Planning Department within two (2) days of the Planning Commission's approval of entitlements. **(California Code Section 15094)**
15. All landscaping shall be maintained in a neat and clean manner, and in conformance with the HBZSO. Prior to removing or replacing any landscaped areas, check with the Departments of Planning and Building, and Public Works for Code requirements. Substantial changes may require approval by the Planning Commission (Zoning Administrator). **(HBZSO Section 232.04)**
16. All permanent, temporary, or promotional signs shall conform to Chapter 233 of the HBZSO. Prior to installing any new signs, changing sign faces, or installing promotional signs, applicable permit(s) shall be obtained from the Planning and Building Department. Violations of this ordinance requirement may result in permit revocation, recovery of code enforcement costs, and removal of installed signs. **(HBZSO Chapter 233)**

Crime Prevention Through Environmental Design



CITY OF HUNTINGTON BEACH POLICE DEPARTMENT

CPTED DEVELOPMENT REVIEW

DATE: JUNE 2, 2022
PROJECT NAME: DIESEL AUTO REPAIR FACILITY
PROJECT LOCATION: 7422 WARNER AVE.
ASSIGNED PLANNER: ALYSSA HELPER
PLAN REVIEWER: JAN THOMAS, CPTED CONSULTANT - HBPD
TELEPHONE/E-MAIL: (949) 290-1604/ iae@cox.net

PROJECT DESCRIPTION: DIESEL AUTO REPAIR FACILITY

The following is a list of code requirements deemed applicable to the proposed project based on plans stated above. The list is intended to assist the applicant by identifying requirements, which must be satisfied during the various stages of project permitting and implementation. A list of conditions of approval adopted by the Planning Commission in conjunction with the requested entitlement(s), if any, will also be provided upon final project approval. If you have any questions regarding these requirements, please contact the Plan Reviewer.

LIGHTING AND SURVEILLANCE

Note: Landscaping is low and appears well-designed to allow surveillance opportunities onto the property.

Ensure the trash dumpster in the southeast corner is illuminated throughout all hours of darkness, as well as the entire perimeter of the building and parking area.

DRIVEWAY ENTRANCE FROM PALMDALE

Include enhanced paving at the driveway entrance on Palmdale to enable motorists to quickly identify the driveway, thus reducing confusion, and possibly avoiding a potential collision.



CITY OF HUNTINGTON BEACH

PROJECT IMPLEMENTATION CODE REQUIREMENTS

DATE: MAY 24, 2022
PROJECT NAME: NEW REPAIR GARAGE
PLANNING APPLICATION NO.: PA-2022-0029
ENTITLEMENTS: CUP-2022-006
DATE OF PLANS: FEBRUARY 1, 2022
PROJECT LOCATION: 7422 WARNER
PROJECT PLANNER: ALYSSA HELPER, ASSOCIATE PLANNER
PLAN REVIEWER: STEVE EROS, DEPUTY FIRE MARSHAL
TELEPHONE/E-MAIL: (714) 536-5531 / Steve.Eros@surfcity-hb.org

PROJECT DESCRIPTION: Establish a new diesel auto repair facility; construct a new 2,000 square foot metal building on an existing vacant lot. A CUP is being requested at this time.

The following is a list of code requirements deemed applicable to the proposed project based on plans received and dated February 1, 2022. The list is intended to assist the applicant by identifying requirements which must be satisfied during the various stages of project permitting and implementation. A list of conditions of approval adopted by the Planning Commission in conjunction with the requested entitlement(s), if any, will also be provided upon final project approval. The review comments below are not to be construed as being all inclusive. **The project is required to comply with all of the adopted Building, Fire, and Municipal Codes in effect at the time of grading and building plan submittal for permit issuance.** If you have any questions regarding these requirements, please contact the Plan Reviewer- Fire: Steve Eros, Deputy Fire Marshal.

PRIOR TO DEMOLITION, GRADING, SITE DEVELOPMENT, ISSUANCE OF GRADING PERMITS, BUILDING PERMITS, AND/OR CONSTRUCTION, THE FOLLOWING SHALL BE REQUIRED:

1. Environmental

The following items shall be completed prior to rough or precise grading plan approval.

Imported Soil Plan. All imported soil shall meet *City Specification #431-92, Soil Cleanup Standards*. An "Imported Soil Work Plan" must be submitted to the Fire Department for review and approval prior to importing any soil from off site. Once approved, the soil source can be sampled per the approved work plan, then results sent to the HBFD for review. No rough grade will be approved prior to the actual soil source approval. Multiple

soil sources required separate sampling as per the approved work plan, with no soil being imported until each source has been verified to meet the CS #431-92 requirements. **(FD)**

2. Fire Protection Systems

The following items shall be completed prior to issuance of a certificate of occupancy.

Fire Extinguishers shall be installed and located in all areas to comply with Huntington Beach Fire Code standards found in *City Specification #424*. The minimum required dry chemical fire extinguisher size is 2A 10BC and shall be installed within 75 feet travel distance to all portions of the building. Extinguishers are required to be serviced or replaced annually. **(FD)**

Rated Assemblies shall comply with Chapter 7 of the California Building Code. The east exterior wall is proposed on the property line so the exterior wall shall not be allowed to have openings and the wall will be fire rated as required by the California Building Code. **(FD)**

3. Fire Personnel Access

The following items shall be completed prior to issuance of a certificate of occupancy.

Main Secured Building Entries shall utilize a KNOX[®] Fire Department Access Key Box, installed and in compliance with City Specification #403, Fire Access for Pedestrian or Vehicular Security Gates & Buildings. Please contact the Huntington Beach Fire Department Administrative Office at (714) 536-5411 for information. Reference compliance with City Specification #403 - KNOX[®] Fire Department Access in the building plan notes. **(FD)**

4. Addressing and Street Names

The following items shall be completed prior to issuance of a certificate of occupancy.

Commercial Building Address Numbers shall be installed to comply with City Specification #428, Premise Identification. Building address number sets are required on front and rear of the structure and shall be a minimum of six inches (6") high with one and one half inch (1 ½") brush stroke. Note: Units shall be identified with numbers per City Specification # 409 Street Naming and Address Assignment Process. Unit address numbers shall be a minimum of four inches (4") affixed to the units front and rear door. All address numbers are to be in a contrasting color. For Fire Department approval, reference

compliance with City Specification #428 Premise Identification in the plan notes and reflect the address location on the building. **(FD)**

GIS Mapping Information

The following items shall be completed prior to issuance of a certificate of occupancy.

- a. **GIS Mapping Information** shall be provided to the Fire Department in compliance with GIS Department CAD Submittal Guideline requirements. Minimum submittals shall include the following:
 - Site plot plan showing the building footprint.
 - Specify the type of use for the building
 - Location of electrical, gas, water, sprinkler system shut-offs.
 - Fire Sprinkler Connections (FDC) if any.
 - Knox Access locations for doors, gates, and vehicle access.
 - Street name and address.

THE FOLLOWING SHALL BE MAINTAINED DURING CONSTRUCTION:

- Fire/Emergency Access And Site Safety shall be maintained during project construction phases in compliance with CFC Chapter 33, Fire Safety During Construction And Demolition. **(FD)**

OTHER:

- Discovery of additional soil contamination or underground pipelines, etc., must be reported to the Fire Department immediately and the approved work plan modified accordingly in compliance with City Specification #431-92 Soil Clean-Up Standards. **(FD)**
- Outside City Consultants. The Fire Department review of this project and subsequent plans may require the use of City Consultants. The Huntington Beach City Council approved fee schedule allows the Fire Department to recover consultant fees from the applicant, developer or other responsible party. **(FD)**

Fire Department City Specifications may be obtained at:

Huntington Beach Fire Department Administrative Office

City Hall 2000 Main Street, 5th floor

Huntington Beach, CA 92648

or through the City's website at

http://www.huntingtonbeachca.gov/government/departments/Fire/fire_prevention_code_enforcement/fire_dept_city_specifications.cfm


If you have any questions, please contact the Fire Prevention Division at (714) 536-5411.



CITY OF HUNTINGTON BEACH

PUBLIC WORKS INTERDEPARTMENTAL COMMUNICATION

PROJECT IMPLEMENTATION CODE REQUIREMENTS

DATE: MAY 20, 2022
PROJECT NAME: DIESEL AUTO REPAIR FACILITY
ENTITLEMENTS CUP-2022-006
PLNG APPLICATION NO. PA-2022-0029
DATE OF PLANS: FEBRUARY 1, 2022
PROJECT LOCATION: 7422 WARNER AVENUE
PROJECT PLANNER ALYSSA HELPER, ASSOCIATE PLANNER
PLAN REVIEWER: JACOB AUBE, SENIOR CIVIL ENGINEER 
TELEPHONE/E-MAIL: 714-375-5123 / JACOB.AUBE@SURFCITY-HB.ORG
PROJECT DESCRIPTION: CONSTRUCT A NEW 2,000 SF DIESEL AUTO REPAIR FACILITY

The following is a list of code requirements deemed applicable to the proposed project based on plans as stated above. The items below are to meet the City of Huntington Beach's Municipal Code (HBMC), Zoning and Subdivision Ordinance (ZSO), Department of Public Works Standard Plans (Civil, Water and Landscaping) and the American Public Works Association (APWA) Standards Specifications for Public Works Construction (Green Book), and the Orange County Drainage Area management Plan (DAMP). The list is intended to assist the applicant by identifying requirements which shall be satisfied during the various stages of project permitting, implementation and construction. If you have any questions regarding these requirements, please contact the Plan Reviewer or Project Planner.

THE FOLLOWING DEVELOPMENT REQUIREMENTS SHALL BE COMPLETED PRIOR TO ISSUANCE OF A GRADING PERMIT:

1. A Precise Grading Plan, prepared by a Licensed Civil Engineer, shall be submitted to the Public Works Department for review and approval. (MC 17.05/ZSO 230.84) The plans shall comply with Public Works plan preparation guidelines and include the following improvements on the plan:
 - a. Curb, gutter, and sidewalk along the Warner Avenue frontage shall be removed and replaced per Public Works Standard Plan Nos. 202 and 207. (ZSO 230.84)
 - b. The cross gutter and corner spandrel shall be removed and replaced per Public Works Standard Plan No. 205 to the centerline of Palmdale Lane. (ZSO 230.84)
 - c. Curb, gutter, and sidewalk along the Palmdale Lane frontage shall be constructed per Public Works Standard Plan Nos. 202 and 207. (ZSO 230.84)
 - d. The driveway approach on Palmdale Lane shall be constructed per Public Works Standard Plan No. 211. (ZSO 230.84)

- e. The existing driveway approach on Warner Avenue shall be removed and replaced with curb, gutter, and sidewalk per Public Works Standard Plan Nos. 202 and 207. (ZSO 230.84)
 - f. An ADA compliant access ramp shall be constructed at the Warner Avenue and Palmdale Lane corner per Caltrans Standard Plan A88A. (ZSO 230.84, ADA)
 - g. A new sewer lateral shall be installed connecting to the main in the street or alley. If the new sewer lateral is not constructed at the same location as the existing lateral, then the existing lateral shall be severed and capped at the main or chimney. (ZSO 230.84)
 - h. A new domestic water service and meter shall be installed per Water Division Standards, and sized to meet the minimum requirements set by the California Plumbing Code (CPC)
 - i. A separate backflow protection device shall be installed per Water Division Standards for domestic water service and shall be screened from view. (Resolution 5921 and State of California Administrative Code, Title 17)
 - j. The existing domestic water service and meter, if not being used, shall be abandoned per Water Division Standards. (ZSO 230.84)
2. A Project Water Quality Management Plan (WQMP) conforming to the current Waste Discharge Requirements Permit for the County of Orange (Order No. R8-2009-0030) [MS4 Permit] prepared by a Licensed Civil Engineer, shall be submitted to the Department of Public Works for review and acceptance. The WQMP shall address Section XII of the MS4 Permit and all current surface water quality issues.
3. The project WQMP shall include the following:
- a. Discusses regional or watershed programs (if applicable).
 - b. Addresses Site Design BMPs (as applicable) such as minimizing impervious areas, maximizing permeability, minimizing directly connected impervious areas, creating reduced or “zero discharge” areas, and conserving natural areas.
 - c. Identifies selected Low Impact Development (LID) and Hydromodification (as applicable) BMPs.
 - d. Incorporates the *Guidelines for Use of Drywells in Stormwater Management Applications* (if applicable).
 - e. Incorporates the applicable Routine Source and Structural Control BMPs as defined in the Drainage Area Management Plan. (DAMP)
 - f. Incorporates GIS or GPS coordinates for all structural and LID BMPs.
 - g. Describes the long-term operation and maintenance requirements for the Structural and Treatment Control BMPs, including maintenance of BMPs as shown on the landscape plans and are described in the WQMP.
 - h. Identifies the entity that will be responsible for long-term operation, maintenance, repair and/or replacement of the Structural and Treatment Control BMPs.
 - i. Describes the mechanism for funding the long-term operation and maintenance of all the Structural and Treatment Control BMPs.
 - j. Includes an Operations and Maintenance (O&M) Plan for all structural and Treatment Control BMPs including anticipated maintenance costs.
 - k. Vector Control Clearance letter from the Orange County Vector Control stating that they have reviewed the project WQMP and proposed BMPs.

- l. After incorporating plan check comments of Public Works, three final WQMPs (signed by the owner and the Registered Civil Engineer of record) shall be submitted to Public Works for acceptance. After acceptance, two copies of the final report shall be returned to applicant for the production of a single complete electronic copy of the accepted version of the WQMP on CD media that includes:
 - i. The 11" by 17" Site Plan in .TIFF format (400 by 400 dpi minimum).
 - ii. The remainder of the complete WQMP in .PDF format including the signed and stamped title sheet, owner's certification sheet, Inspection/Maintenance Responsibility sheet, appendices, attachments and all educational material.
 - m. The applicant shall return one CD media (with a copy of the approved WQMP) to Public Works for the project record file.
4. Indicate the type and location of Water Quality Treatment Control Best Management Practices (BMPs) on the Grading Plan consistent with the Project WQMP. The WQMP shall follow the City of Huntington Beach; Project Water Quality Management Plan Preparation Guidance Manual dated June 2008. The WQMP shall be submitted with the first submittal of the Grading Plan.
 5. A suitable location, as approved by the City, shall be depicted on the grading plan for the necessary trash enclosure(s). The area shall be paved with an impervious surface, designed not to allow run-on from adjoining areas, designed to divert drainage from adjoining roofs and pavements diverted around the area, and screened or walled to prevent off-site transport of trash. The trash enclosure area shall be covered or roofed with a solid, impervious material. Connection of trash area drains into the storm drain system is prohibited. If feasible, the trash enclosure area shall be connected into the sanitary sewer. (DAMP)
 6. A detailed soils and geological/seismic analysis shall be prepared by a registered engineer. This analysis shall include on-site soil sampling and laboratory testing of materials to provide detailed recommendations for grading, over excavation, engineered fill, dewatering, settlement, protection of adjacent structures, chemical and fill properties, liquefaction, retaining walls, streets, and utilities. (MC 17.05.150)
 7. The applicant's grading/erosion control plan shall abide by the provisions of AQMD's Rule 403 as related to fugitive dust control. (AQMD Rule 403)
 8. The name and phone number of an on-site field supervisor hired by the developer shall be submitted to the Planning and Public Works Departments. In addition, clearly visible signs shall be posted on the perimeter of the site every 250 feet indicating who shall be contacted for information regarding this development and any construction/grading-related concerns. This contact person shall be available immediately to address any concerns or issues raised by adjacent property owners during the construction activity. That person will be responsible for ensuring compliance with the conditions herein, specifically, grading activities, truck routes, construction hours, noise, etc. Signs shall include the applicant's contact number, regarding grading and construction activities, and "1-800-CUTSMOG" in the event there are concerns regarding fugitive dust and compliance with AQMD Rule No. 403.
 9. The applicant shall notify all property owners and tenants within 300 feet of the perimeter of the property of a tentative grading schedule at least 30 days prior to such grading.

**THE FOLLOWING DEVELOPMENT REQUIREMENTS SHALL BE COMPLIED WITH DURING
GRADING OPERATIONS:**

10. An Encroachment Permit is required for all work within the City's right-of-way. (MC 12.38.010/MC 14.36.030)

11. The developer shall coordinate the development of a truck haul route with the Department of Public Works if the import or export of material in excess of 5000 cubic yards is required. This plan shall include the approximate number of truck trips and the proposed truck haul routes. It shall specify the hours in which transport activities can occur and methods to mitigate construction-related impacts to adjacent residents. These plans must be submitted for approval to the Department of Public Works. (MC 17.05.210)
12. Water trucks will be utilized on the site and shall be available to be used throughout the day during site grading to keep the soil damp enough to prevent dust being raised by the operations. (California Stormwater BMP Handbook, Construction Wind Erosion WE-1)
13. All haul trucks shall arrive at the site no earlier than 8:00 a.m. or leave the site no later than 5:00 p.m., and shall be limited to Monday through Friday only. (MC 17.05)
14. Wet down the areas that are to be graded or that is being graded, in the late morning and after work is completed for the day. (WE-1/MC 17.05)
15. The construction disturbance area shall be kept as small as possible. (California Stormwater BMP Handbook, Construction Erosion Control EC-1) (DAMP)
16. All haul trucks shall be covered or have water applied to the exposed surface prior to leaving the site to prevent dust from impacting the surrounding areas. (DAMP)
17. Prior to leaving the site, all haul trucks shall be washed off on-site on a gravel surface to prevent dirt and dust from leaving the site and impacting public streets. (DAMP)
18. Comply with appropriate sections of AQMD Rule 403, particularly to minimize fugitive dust and noise to surrounding areas. (AQMD Rule 403)
19. Wind barriers shall be installed along the perimeter of the site. (DAMP)
20. All construction materials, wastes, grading or demolition debris and stockpiles of soils, aggregates, soil amendments, etc. shall be properly covered, stored and secured to prevent transport into surface or ground waters by wind, rain, tracking, tidal erosion or dispersion. (DAMP)

**THE FOLLOWING DEVELOPMENT REQUIREMENTS SHALL BE COMPLETED PRIOR TO
ISSUANCE OF A BUILDING PERMIT:**

21. A Precise Grading Permit shall be issued. (MC 17.05)
22. Traffic Impact Fees (TIF) for the project shall be paid at or prior to Building Permit issuance. The current fee rate for this project is \$2,601.82/tsf. The rate is subject to an annual adjustment. (MC 17.65)
23. A drainage fee for the subject development shall be paid at the rate applicable at the time of Building Permit issuance. The current rate of \$14,888 per gross acre is subject to periodic adjustments. This project consists of 0.40 gross acres (including its tributary area portions along the half street frontages) for a total required drainage fee of \$5,964. City records indicate the previous use on this property never paid this required fee. Per provisions of the City Municipal Code, this one-time fee shall be paid for all subdivisions or development of land. (MC 14.48)
24. The applicable Orange County Sanitation District Capital Facility Capacity Charge shall be paid to the City Department of Public Works. (Ordinance OCSD-57)

**THE FOLLOWING DEVELOPMENT REQUIREMENTS SHALL BE COMPLETED PRIOR TO
ISSUANCE OF AN ENCROACHMENT PERMIT:**

25. Traffic Control Plans, prepared by a Licensed Civil or Traffic Engineer, shall be prepared in accordance with the latest edition of the City of Huntington Beach Construction Traffic Control Plan Preparation

Guidelines and submitted for review and approval by the Public Works Department. (Construction Traffic Control Plan Preparation Guidelines)

THE FOLLOWING DEVELOPMENT REQUIREMENTS SHALL BE COMPLETED PRIOR TO FINAL INSPECTION OR OCCUPANCY:

26. Complete all improvements as shown on the approved grading and improvement plans. (MC 17.05)
27. All new utilities shall be undergrounded. (MC 17.64)
28. All applicable Public Works fees shall be paid at the current rate unless otherwise stated, per the Public Works Fee Schedule adopted by the City Council and available on the city web site at http://www.surfcity-hb.org/files/users/public_works/fee_schedule.pdf. (ZSO 240.06/ZSO 250.16)
29. Prior to grading or building permit close-out and/or the issuance of a certificate of use or a certificate of occupancy, the applicant shall:
 - a. Demonstrate that all structural Best Management Practices (BMPs) described in the Project WQMP have been constructed and installed in conformance with approved plans and specifications.
 - b. Demonstrate all drainage courses, pipes, gutters, basins, etc. are clean and properly constructed.
 - c. Demonstrate that applicant is prepared to implement all non-structural BMPs described in the Project WQMP.
 - d. Provide certifications from the Engineer of Record or Landscape Architect that the LID BMPs were constructed and installed per the approved project plans and specifications. The certifications shall be included in the final WQMP.
 - e. Demonstrate that an adequate number of copies of the approved Project WQMP are available for the future occupiers.
 - f. Demonstrate that the preparer of the WQMP has reviewed the BMP maintenance requirements in Section V of the WQMP with the responsible person and that a copy of the WQMP has been provided to that person. A certification letter from the WQMP preparer may be used to satisfy this condition.



CITY OF HUNTINGTON BEACH

PROJECT IMPLEMENTATION CODE REQUIREMENTS

DATE: 03/10/2022
PROJECT NAME: Logic Diesel and Automotive Service
PLANNING APPLICATION NO.: PA-2022-0029
ENTITLEMENTS:
PROJECT LOCATION: 7422 Warner Avenue
PLAN REVIEWER: Kevin Kirby
TELEPHONE/E-MAIL: (714) 374-5324 / kkirby@surfcity-hb.org

The following is a list of code requirements deemed applicable to the proposed project based on plans stated above. The list is intended to assist the applicant by identifying requirements which must be satisfied during the various stages of project permitting and implementation. A list of conditions of approval adopted by the Planning Commission in conjunction with the requested entitlement(s), if any, will also be provided upon final project approval. If you have any questions regarding these requirements, please contact the Plan Reviewer.

➤ **REQUIREMENT:**

1. Development Impact Fees will be required for new construction and commercial/industrial additions.
2. Submit separate plans for all disciplines. If hard copies are submitted, please provide Building 3 sets and MEP 2 sets each
3. Landscape plan is a separate submittal for irrigation and plants only. No accessory structures or flat work will be reviewed on the landscape plans.
4. **All site work for accessibility will be reviewed and inspected based on the approved architectural plans.**
5. All accessory and minor accessory structures including site MEP will be on separate permits.

➤ **CODE REQUIREMENTS BASED ON PLANS & DRAWINGS SUBMITTED:**

1. Project shall comply with the current State building codes adopted by the City at the time of permit application submittal. Currently they are the 2019 California Building Code (CBC), 2019 California Residential Code (CRC), 2019 California Mechanical Code, 2019 California Plumbing Code, 2019 California Electrical Code, 2019 California Energy Code, 2019 California Green Building Standards Code, and the Huntington Beach Municipal Code

(HBMC). Compliance to all applicable state and local codes is required prior to issuance of building permit.

2. Provide all project implementation code requirements and conditions of approval on the approved building plans
3. Provide building code analysis including type of construction, allowable area and height, occupancy group requirements, exterior wall ratings (per chapter 5 and 7), and means of egress per the 2019 CBC.
4. Provide compliance to disabled accessibility requirements of Chapter 11B of the 2019 CBC. Including an accessible path of travel to the public way.
5. Review and provide compliance with Title 17 of the City of Huntington Beach Municipal Code, Building and Construction. This document can be found online at the city's website.
6. For projects that will include multiple licensed professions in multiple disciplines, i.e. Architect and professional engineers for specific disciplines, a Design Professional in Responsible Charge will be requested per the 2019 CBC, Section 107.3.4.
7. In addition to all of the code requirements of the 2019 California Green Building Standards Code, specifically address Construction Waste Management per Sections 4.408.2, 4.408.3, 4.408.4, 5.408.1.1, 5.408.1.2, 5.408.1.3 and Building Maintenance and Operation, Section 5.410. Prior to the issuance of a building permit, the permittee will be required to describe how they will comply with the sections described above. Prior to Building Final Approval, the City will require a Waste Diversion Report per Sections 4.408.5 and 5.408.1.4.
8. The City of Huntington Beach has adopted the 2019 California Green Building Standards Code, including Sections 4.106.4.1 for Electric Vehicle (EV) Charging for New Construction, and 5.106.5.3 Electric Vehicle (EV) Charging.
9. The City of Huntington Beach has adopted the 2019 California Green Building Standards Code including section 301.1.1 where all non-compliant fixtures shall be replaced with water conserving fixtures as described in section 403.3.1. Non-compliant fixtures are defined in section 1101.3(c) of the California Civil Code.

➤ **COMMENTS:**

1. Project "*Condition of Approval*" shall appear on the submitted drawings.
2. Plans shall show justifications for allowable floor areas and the number of stories.
3. **Exiting Plan & Analysis:** Plans should include an occupant load analysis on the plans and provide an "Exit Plan" to show a clear and dimensioned Means of Egress system that

provides a continuous, unobstructed exit from any occupied point in the building to a public way.

4. **Fire-rated Construction:** Plans should clearly identify the locations of the Fire Areas, Fire Walls, Fire Barriers, Fire Partitions, and all Occupancy separations. Provide complete legends and details on the plans.
5. Plans should clearly show compliance with CBC Chapters 11B Accessibility to Public Buildings, Public Accommodations, Commercial Buildings and Public Housing). A Certified Access Specialist (CASP) report is recommended and shall be incorporated onto the plans
6. If exterior trash enclosure is provided, it shall to be covered.
7. Per 11B-208.2.4 2019 CBC The accessible parking space is required to be a van accessible space
8. Per 11B-502.2 the accessible van parking space shall be 144 Inches wide minimum
9. The parking identification sign shall comply with 11B-502.6 in its entirety
10. An additional sign commonly referred to as the tow information signage shall be placed in a conspicuous space complying with section 11B-502.8 in its entirety
11. The proposed electrical meter cannot be located where it encroaches into the vertical clearance required by 11B-502.5 for the access aisle.