



Fire Code Amendment

Fire Access Requirements

**SUPPLEMENTAL
COMMUNICATION**

Meeting Date:

9/6/2022

Agenda Item No.:

#33 (22-714)

New Fire Access Requirements

Main Changes

- Extend fire access dimension from 150' to 200'.
- Specify the required fire features when fire access exceeds 150'.

Advantages

- Consistency for Developers
- Streamlines Design Process
- Reduces Need for AM&M
- Enhanced Fire Protection Systems



New Fire Access Requirements

