

**ATTACHMENT NO. 1**

**FINDINGS AND CONDITIONS OF APPROVAL**

**COASTAL DEVELOPMENT PERMIT NO. 19-006**

**FINDINGS FOR PROJECTS EXEMPT FROM CEQA:**

The Zoning Administrator finds that the project will not have any significant effect on the environment and is exempt from the provisions of the California Environmental Quality Act (CEQA) pursuant to Section 15302 of the CEQA Guidelines, because the project involves the removal of an existing street light pole and the replacement of a new street light pole on the same site, and includes the installation of small new equipment for a wireless communication facility.

**FINDINGS FOR APPROVAL – COASTAL DEVELOPMENT PERMIT NO. 19-006:**

1. Coastal Development Permit No. 19-006 to remove an existing 23 ft. 9 in. high light pole and replace with a new 24 ft. 1 in. high light pole to install small cell wireless equipment at an overall height of 27 ft. 2 in. and new underground infrastructure in the public right-of-way located in the Coastal Zone conforms with the General Plan, including the Local Coastal Program in that it is consistent with Coastal Element Land Use Policy C 4.2.4, that wireless communication facilities shall be sited, to the maximum extent feasible, to minimize visual resource impacts. The proposed wireless communication facility's stealth design will minimize any visual impacts by co-locating on an existing street light pole, painting the facility to match existing pole, and locate accessory equipment below ground. The proposed wireless telecommunication facility will occur within the public right of way contiguous to existing residential development and will enhance the provision of personal communication capacity within the Coastal Zone.
2. The granting of Coastal Development Permit No. 19-006 to remove an existing 23 ft. 9 in. high light pole and replace with a new 24 ft. 1 in. high light pole to install small cell wireless equipment at an overall height of 27 ft. 2 in. and new underground infrastructure in the public right-of-way and Coastal Zone is consistent with the requirements of the CZ Overlay District, the base zoning district, as well as other applicable provisions of the Municipal Code because the proposed light pole replacement, including small cell wireless communications facility equipment, will comply with all applicable stealth design regulations to minimize visual impacts of the equipment.
3. Coastal Development Permit No. 19-006 to remove an existing 23 ft. 9 in. high light pole and replace with a new 24 ft. 1 in. high light pole to install small cell wireless equipment at an overall height of 27 ft. 2 in. and new underground infrastructure in the public right-of-way and Coastal Zone can be provided with infrastructure in a manner that is consistent with the Local Coastal Program because the wireless telecommunication facility will be within the public right-of-way in an urbanized area with all necessary services and infrastructure available, including electricity and roadways.
4. The proposed removal of an existing 23 ft. 9 in. high light pole and replacement with a new 24 ft. 1 in. high light pole to install small cell wireless equipment at an overall height of 27 ft. 2 in. and new underground infrastructure in the public right-of-way and Coastal Zone conforms

with the public access and public recreation policies of Chapter 3 of the California Coastal Act in that the project will not impede public access, recreation, or views to coastal resources.

**CONDITIONS OF APPROVAL - COASTAL DEVELOPMENT PERMIT NO. 19-006:**

1. The site plan, photo simulations, and elevations received and dated March 29, 2019 shall be the conceptually approved design.
2. Prior to the issuance of a building permit, site specific traffic control plans shall be prepared and submitted for review and approved by Public Works prior to obtaining an encroachment permit. **(PW)**
3. Construction plans shall be prepared for review and approval by Public Works. The plan shall comply with Huntington Beach codes, standards and specifications. Plan shall include, but is not limited to:
  - a. The WTR/FSB (cut-off switch) shall be located no more than 20-feet from the base of the utility pole. Pull-box cover shall be permanently engraved with emergency contact phone number and address of site served by cut-off switch. **(PW)**
  - b. All pole mounted equipment/antenna(s) and brackets shall be painted to match pole. **(PW)**
  - c. The final Southern California Edison (SCE) power design shall be provided. **(PW)**
  - d. City pull boxes shall be installed per Public Works Standards. **(PW)**
  - e. New street light poles shall be coated with Amershield anti-graffiti coating. **(PW)**
  - f. Reconstructed improvements shall be identified on the plans and installed per Public Works Standards. **(PW)**
4. During demolition, grading, site development, and/or construction, the following shall be adhered to:
  - a. Construction equipment shall be maintained in peak operating condition to reduce emissions.
  - b. Use low sulfur (0.5%) fuel by weight for construction equipment.
  - c. Truck idling shall be prohibited for periods longer than 5 minutes.
  - d. Attempt to phase and schedule activities to avoid high ozone days first stage smog alerts.
  - e. Discontinue operation during second stage smog alerts.
  - f. Ensure clearly visible signs are posted on the perimeter of the site identifying the name and phone number of a field supervisor to contact for information regarding the development and any construction/ grading activity.
  - g. Existing fire protection systems on the site shall be maintained operational.
  - h. All conduits to have a maximum offset distance of 3.25 in. from the wood utility pole and shall be painted to match the pole. **(PW)**

- i. All pole mounted equipment/antenna(s) and brackets shall be painted to match the pole. **(PW)**
  - j. The electrical service to the site shall be installed underground (MC 17.64.050). **(PW)**
5. CDP No. 19-006 shall become null and void unless exercised within two years of the date of final approval or such extension of time as may be granted by the Director pursuant to a written request submitted to the Community Development Department a minimum 30 days prior to the expiration date.
6. The Development Services Departments and divisions (Building & Safety, Fire, Planning, and Public Works) shall be responsible for ensuring compliance with all applicable code requirements and conditions of approval. The Director of Community Development may approve minor amendments to plans and/or conditions of approval as appropriate based on changed circumstances, new information or other relevant factors. Any proposed plan/project revisions shall be called out on the plan sets submitted for building permits. Permits shall not be issued until the Development Services Departments have reviewed and approved the proposed changes for conformance with the intent of the Zoning Administrator's action. If the proposed changes are of a substantial nature, an amendment to the original entitlement reviewed by the Zoning Administrator may be required pursuant to the provisions of HBZSO Section 241.18.

**INDEMNIFICATION AND HOLD HARMLESS CONDITION:**

The owner of the property which is the subject of this project and the project applicant if different from the property owner, and each of their heirs, successors and assigns, shall defend, indemnify and hold harmless the City of Huntington Beach and its agents, officers, and employees from any claim, action or proceedings, liability cost, including attorney's fees and costs against the City or its agents, officers or employees, to attack, set aside, void or annul any approval of the City, including but not limited to any approval granted by the City Council, Planning Commission, or Design Review Board concerning this project. The City shall promptly notify the applicant of any claim, action or proceeding and should cooperate fully in the defense thereof.